



Rev. 02/2025

## AIRSPOT 60C

Decentralized heat recovery unit.

### LED SIGNALING LEGEND

## LED SIGNALING LEGEND

— Long flashing

■ Short flashing


Key		 EXTRACTION	 INTAKE	 AUTOMATIC CYCLE
	High speed	■ ■ ■	■ ■ ■	■ ■ ■ ■ ■
	Medium speed	■ ■	■ ■	■ ■ ■ ■
	Low speed	■	■	■ ■
	Minimum speed (night)	■ ■ ■	■ ■ ■	■ ■ ■ ■

Key		
	Off mode	■ ■ ■ ■ ■


## HUMIDITY SENSOR

Key		
	Sensor inactive	■ ■ ■ ■ ■
	Low humidity 55%	■
	Medium humidity 60%	■ ■
	High humidity 65%	■ ■ ■

## AIR QUALITY SENSOR - VOC

Key		
	Sensor inactive	■ ■ ■ ■ ■
	Air quality EXCELLENT	■
	Air quality GOOD	■ ■
	Air quality MEDIUM	■ ■ ■

## TWILIGHT SENSOR

Key		
	Sensor inactive	■ ■ ■ ■ ■
	Speed reduction in the dark	■
	Speed reduction with shadow	■ ■
	Speed reduction in semi-darkness	■ ■ ■

## FILTER CLEANING

Key		
	Filter cleaning required	■ ■ ■ ■ ■ (every 60 minutes)
	Filter cleaning signal reset confirmation	□ □

*RBM spa reserves the right to improve and change the products described and relevant technical data at any moment and without prior notice. The information and images contained in this document are intended for information purposes only, are not binding and in any case do not exempt the user from strictly following the regulations in force and good practice standards.*

**RBM Spa**  
Via S. Giuseppe, 1 • 25075 Nave (Brescia) Italy  
Tel 030 2537211 • Fax 030 2531798 • info@rbm.eu • www.rbm.eu

 @rbmspa  RBM S.p.A.  rbm\_spa\_  Rbm Italia